ONICON

Flow and Energy Measurement

SYSTEM-1000
MOUNTING TEMPLATE AND INSTRUCTIONS

STEP 2

STEP 2

ONICON
Flow and Energy Measurement

10.90"

4 x ⌀ 0.28"

11.25"

THE MOUNTING SURFACE MUST BE STRUCTURALLY SOUND AND CAPABLE OF WITHSTANDING
A MINIMUM WEIGHT OF 60LBS (27KG). USE THE FOLLOWING HARDWARE FOR MOUNTING.

CONCRETE, BLOCK & BRICK
(4) 1/4" X 1-1/2" HEX HEAD CONCRETE SCREWS THAT SUPPORTS A MINIMUM OF 60LBS

DIN 3 RAIL
(4) SINGLE CLIP MOUNTING ADAPTER FOR DIN 3 RAIL

WOOD:
(4) 1/4" X 1-1/2" HEX HEAD LAG SCREWS THAT SUPPORTS A MINIMUM OF 60LBS

DRYWALL:
(4) #12 X 1-1/2" HEX HEAD SCREW
(4) #12 WASHERS
(4) DRYWALL ANCHORS THAT SUPPORT A MINIMUM OF 60 LBS

CENTERLINE
USE FOR LEVELING

10.90"

11.25"

SYSTEM-1000 Series
Flow and Energy Measurement System

4 x ⌀ 0.28

Image not to scale